

Lilly Borough Water Authority

LILLY, PENNSYLVANIA

RESOLUTION

Resolution No.: June-2020-1

*A Resolution of the Lilly Borough Water
Authority Providing for Mandatory
Calibration of Water Meters*

WHEREAS, the Authority has determined that to ensure accurate measurement of flow through the Water System, the calibration of the meters is necessary; and

WHEREAS, the Authority has adopted the "Rates and Rules for the Supply of Water in the Borough of Lilly and Township of Washington Pennsylvania" ("Rates and Rules"); and

WHEREAS, by approval of this Resolution, the Authority is hereby and herein amending the Rates and Rules to include calibration requirements.

NOW THEREFORE, **BE IT RESOLVED** by the Lilly Borough Water Authority ("LBWA") as follows:

Section 24 of the Rates and Rules shall be amended to include the following:

Source meters installed within the LBWA's service area shall be calibrated annually. Any service larger than 3/4" shall be calibrated every three years. If the LBWA, in its sole discretion determines that a calibration of any meter is necessary, apart from these minimum requirements, it shall have the authority to require same.

RESOLVED this third day of June, 2020

**LILLY BOROUGH WATER
AUTHORITY**

By:



Paul C. Skłodowski - Chairman

Attest:


Claudine M. Falger - Secretary